

Product declaration

The following products used for miter sealing in window frame production were tested by Metalogic NV (Belgium) according to test if the Seaside C5M qualification is reached in the sealed area:



The products were subject to the Filiform corrosion test (Qualicoat specification § 2.19. – based on ISO 4623-2) and the acetic acid salt spray test (Qualicoat Specification §2.10 - ISO 9227 AASS). The test report (211202/NOVA/SV/CT/113) is available on request.

Based on the performed tests the following conclusions can be drawn:

*All reported test results meet the Qualicoat specifications concerning the resistance against filiform corrosion and concerning the acetic acid salt spray test. A Qualicoat Seaside C5M coated miter joint that has been properly sealed with one of these tested products, will retain its seaside corrosion protection and **should be considered equal to a certified C5M seaside coated surface.***

Bram Starckx
Technology Manager

